

OFFICE OF THE MUNICIPAL COUNCIL GAJWEL - PRAGNAPUR
SIDDIPET DIST

No.F1/1394/2026

Date: 01/07/2026

SANITARY CERTIFICATE


This is to certify that there is No Objection to run the **ST MARY'S VIDYANIKETAN HIGH SCHOOL - CBSE** at H No 10-67/1/A, Pragnapur, Gajwel, Siddipet District. The Management provided the sufficient sanitary facilities in and around the School premises. Hence there is No Objection for running the School on Sanitary point of view with the following conditions.


Following conditions must be followed:


1. Subject to condition of structural soundness certificate.
2. NOC from Fire Department.
3. Sufficient number of toilets for boys and girls should be provided separately.
4. Premises should be kept clean & pollution free.
5. If any health-related issues raised to the students of this college/school in future time the Sanitary Certificate will be cancelled automatically without any notice.
6. The generated waste shall be divided into wet, dry & domestic hazardous and give to the municipal vehicles.
7. The Management will not allow single use plastic (SUP) in the college/school Premises.
8. The Management will abide by the Solid Waste Management (SWM) Rules - 2026.
9. They should equip all kinds of fire instruments to prevent fire accidents in the premises.
10. Renewal of Sanitary Certificate every year from this Municipality is Mandatory. This Certificate Valid up to 30/06/2027.


Principal
St.Mary's Vidyaniketan High School
Pregnapur-Gajwel.(D)Siddipet-502311


The Correspondent
St.Mary's Vidyaniketan High School
Pregnapur-Gajwel (M) Siddipet (D)-502 311.


Commissioner
Municipal Council
Gajwel - Pragnapur.


21/7/26


21/7/26

GOVERNMENT OF TELANGANA,
MISSION BHAGIRATHA DEPARTMENT,
OFFICE OF THE DEPUTY EXECUTIVE ENGINEER, MB- INTRA, SUB DIVISION-GAJWEL.

From
Shri A.Praveen Kumar, B.E.,
Deputy Executive Engineer,
MB Intra, Sub Division Gajwel.

To
The Principal,
St.Mary' Vidyaniketan High
School, Pregnapur-Gajwel,
Siddipet District.

Lr.No.AEE/Lab Water Test Report/St.Mary's Vidyaniketan High School/2026-27

Date: 20.05.2026.

Sir,


Sub: MB Intra-Sub Division Gajwel-Submission of Water Quality Test Report
of water samples from St.Mary's Vidyaniketan High School, Pregnapur-
Gajwel-Regarding.

Ref: Letter Dated:14.05.2026 of the Principal, St.Mary's Vidyaniketan High
School, Pregnapur-Gajwel, Siddipet District.

Anent to the reference to the subject cited above, I am here with submitting
the Water quality test report of water samples collected from Borewell located in St.Mary's
Vidyaniketan High School, Pregnapur-Gajwel. Reports are suggested that water is chemically
satisfied and bacteriologically wholesome.

Encl: 1. Lab Report

Yours faithfully,


Dy.Executive Engineer,
MB Intra, SD Gajwel.

Dy.Executive Engineer,
MB-Intra, SD-Gajwel.


Principal

St.Mary's Vidyaniketan High School
Pregnapur-Gajwel.(D)Siddipet-502311


The Correspondent
St.Mary's Vidyaniketan High School
Pregnapur-Gajwel (M) Siddipet (D)-502 311.

**OFFICE OF THE DEPUTY EXECUTIVE ENGINEER
MB SUB DIVISION – GAJWEL DIST SIDDIPET
DRINKING WATER TESTING LAB GAJWEL AT KOMATIBANDA**

Date: 15/05/2026
Mandal: Gajwel

Village: Pragnapur
Location: St Mary's Vaidyanathan high school SPM

Chemical Examination of Sample Water

Sl no	Parameter	Bore water Result	Desirable Limit	Permissible Limit
1	PH	7.10	6.5 – 8.5	No relaxation
2	Alkalinity	484 Mg/liter	200 Mg/liter	600 Mg/liter
3	Chlorides	164 Mg/liter	250 Mg/liter	1000 Mg/liter
4	Hardness	500 Mg/liter	300 Mg/liter	600 Mg/liter
5	Fluoride	1.20 Mg/liter	1.0 Mg/liter	1.5 Mg/liter
6	Iron	0.01 Mg/liter	0.3 Mg/liter	1.0 Mg/liter
7	Sulphate	50 Mg/liter	200 Mg/liter	400 Mg/liter
8	Nitrate	12 Mg/liter	45 Mg/liter	No relaxation
9	TDS	670 Mg/liter	500 Mg/liter	2000 Mg/liter

RESULT: Chemically Satisfied.

Bacteriological Examination of Sample Water

Sl No	Type of source	Name of the Location	MPN of Coliforms/100ml	MPN of E.Coli/100ml
1.	Bore water	In School	0	Nil

RESULT: Bacteriologically wholesome.

Chemist
CHEMIST

Microbiologist
MICROBIOLOGIST

Dy. Executive Engineer
Dy. Executive Engineer,
MB-Intra, SD-Gajwel.

Principal
Principal

St. Mary's Vidyaniketan High School
Pregn timer-Gajwel. (D) Siddipet-502311

The Correspondent
The Correspondent
St. Mary's Vidyaniketan High School
Pregn timer-Gajwel (M) Siddipet (D)-502 311.